



FORM 10

Aon File Reference: M34

<p>LISTING CERTIFICATE – SPRINKLER SYSTEM EQUIPMENT As per section 114 of NZS 4541:2007 and NZS4515:2009 Appendix G</p>	
<p>This is to confirm that, on the basis of the information supplied in the application for listing of the equipment dated 28 August 2014 this organisation, as the nominated Sprinkler System Certifier considers that the appropriate requirements of NZS 4541:2007 and NZS4515:2009 have been adequately met with respect to the item described below, for use under the conditions set out on this certificate.</p>	
<p>Item: Europress press-fit piping system; carbon steel & stainless steel.</p>	
<p>For use as: Piping system for sprinkler systems, size range 15 to 108mm OD</p>	
<p>Certificate number: M34</p>	<p>Effective from: 21/11/2014</p>
<p>Manufacturer / Supplier: Eurotubi Europa Sri/ Waterworks Wholesale</p>	
<p>Make: Europress press-fit piping system</p>	
<p>Model: Zinc coated carbon steel pipe, 304 & 316L stainless steel pipe, fittings and accessories</p>	
<p>Reference information: Europress technical catalogue</p>	
<p>Range limitations: 15 – 108 outside dimension. Minimum working temperature of carbon steel +4C and -20C for stainless steel.</p>	
<p>Restrictions and warnings: Installation to be in accordance with the manufactures recommendations, including pipe support/bracketing distances. Only Europress fittings shall be used with Europress pipe. Correct transition fittings shall be used when connecting to other pipe systems. Only M type pressing jaws shall be used. For sizes 42mm and greater pressing chains shall be employed.</p>	
<p>Special conditions: Carbon steel approved for wet pipe systems only. Stainless steel approved for wet pipe & dry pipe systems. For use with antifreeze and foam only by project specific approval.</p>	
<p>Signed </p>	<p>Date: 21/11/2014</p>
<p>Name: Stephen Ridder</p>	<p>Designation: Fire Protection Consultant IANZ Approved Signatory</p>